



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 416
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

www.lakegovernment.com

ADDENDUM NUMBER 2

Date: May 26, 2010
BID Number 10-0819
Replacement of Leachate Tanks

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Respondents shall acknowledge receipt of this addendum by completing this form and returning it with the response. Failure to acknowledge this addendum may preclude consideration of the bid proposal award.**

Change/add/clarify the following:

- Vendor Equipment Staging– can use the banks of the retention pond.
- Vendor Equipment Staging – can use the area east of the tanks by the Sheriff's garden area (actual area needed will need to be coordinated with the County, prior to mobilization and temporary fencing may be required).
- Road closure to unload equipment, etc is possible and the contractor will need to provide traffic control.
- Replacement of cement floor coating/sealant inside the containment structure may be needed; County will do a separate solicitation if necessary. The successful vendor will take all necessary steps to prevent additional damage to these areas during construction activities. The concrete inside the wetted areas of the storage tanks will be required, per manufacturer's recommendations; compatible for the leachate liquids anticipated to be stored (Laboratory analysis is attached).
- No waiver of landfill fees, however you do not need to dispose at our facility.
- Fencing can be removed for easy access however contractor will need to secure the area every evening and reinstall fencing when project is completed.
- Any solids in tanks will be disposed by the County.
- Location of pipes have to stay where they are now located.
- Original installer of tanks was Florida Aquastore.
- There is no geotechnical report available for this project.

- Limits of work will be required as specified in the bidding documents.
- **New bid opening date is June 23, 2010 at 3:00pm.**

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____

"Earning Community Confidence Through Excellence in Service"

DISTRICT ONE
JENNIFER HILL

DISTRICT TWO
ELAINE RENICK

DISTRICT THREE
JIMMY CONNER

DISTRICT FOUR
LINDA STEWART

DISTRICT FIVE
WELTON G. CADWELL